



TEST REPORT

January, 2007

SUBJECT: Conformance of **PECORA UREXPAN NR-200** to ASTM D-1850-74.

SUMMARY; **PECORA UREXPAN NR-200** was tested in accordance with ASTM D-1850-74 was found to meet or exceed the requirements of the specification.

	<u>TEST</u>	<u>REQUIREMENTS</u>	<u>RESULTS</u>
3.1	Penetration	235 maximum	Passes
3.2	Flow	Cured material shall not flow in excess of 5mm.	Passes
3.3	Bond	Shall not fail in adhesion or cohesion to mortar after 5 cycles.	Passes

CONCLUSIONS: **PECORA UREXPAN NR-200** complies with ASTM D-1850-74.

Pecora R & D, QC, and Technical Service laboratories operate under guidelines set forth under ASTM C-1021, Standard Practice for Laboratories Engaged in Testing of Building Sealants, and meet all listed qualifications to perform the testing reported above.